



# CB TEST CERTIFICATE

Ref. Certificate No.

NL-18018

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Moulded case circuit-breaker		
Applicant:	SASSIN INTERNATIONAL ELECTRIC SHANGHAI Co., Ltd	NO,2588 JINHAI ROAD, PUDONG, SHANGHAI	China
Manufacturer:	SASSIN INTERNATIONAL ELECTRIC SHANGHAI Co., Ltd	NO,2588 JINHAI ROAD, PUDONG, SHANGHAI	China
Factory:	SASSIN INTERNATIONAL ELECTRIC SHANGHAI Co., Ltd	NO,2588 JINHAI ROAD, PUDONG, SHANGHAI	China
Rating and principal characteristics:	3P / 3P+N; Ue = 400 Vac; Ie = 160 A, 180 A, 200 A, 225 A, 250 A; Uimp = 6 kV; Ui = 500 V; Icu = 50 kA, Ics = 75% Icu (3SM29-250S); Icu = 35 kA, Ics = 100% Icu (3SM29-250N); 50 / 60 Hz; Utilization Category A.		
Trade mark (if any):	SASSIN		
Model/Type reference:	3SM29-250S, 3SM29-250N		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-1(ed.5) 60947-2(ed.4);am1		
Test Report Ref. No:	3300912.50		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.  
Utrechtseweg 310  
P.O. Box 5185  
6802 ED Arnhem  
The Netherlands

# KEMA Quality

a DEKRA company

Signed by: F.S.Strikwerda

Date of issue: 2010-04-09